



TYPE APPROVAL CERTIFICATE

Certificate No:
TAE00001NX
Revision No:
1

This is to certify:

That the **Electrical Equipment**

with type designation(s)
Explosion Protected Plug and Socket Device 16A 5516//**/(*****)**

Issued to
WISKA Hoppmann GmbH
Kaltenkirchen, Germany

is found to comply with
DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Temperature -40°C=Ta=+40°C (T6/65°C) / -40°C=Ta=+55°C (T5/65°C)
Humidity up to 95%
Vibration -

Issued at **Høvik** on **2022-02-16**

This Certificate is valid until **2027-02-15**.

for **DNV**

DNV local station: **Hamburg**

Approval Engineer: **Maik Gagern**

.....
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description*

Explosion Protected Plug and Socket Device

Type: 5516/**/**/(*****)Plug and Socket-outlet 2-pole + PE, 110-130 V (4 h) or 220-250 V (6 h),
Switching capacity: AC-3 16A 690V

Degree of protection : IP 66
Degree of explosion protection : II 2 G Ex de IIC T5/T6 Gb
II 2 D Ex tb IIIC T65°C Db

Temperature range : -40°C≤Ta≤+40°C (T6/65°C)
-40°C≤Ta≤+55°C (T5/65°C)

Application/Limitation

*Note: All details about electrical explosion protection mentioned in this certificate are for information only. For relevant binding information the corresponding Certificate of Conformity with regard to electrical explosion protection, issued by a recognised Authority, shall be observed.

Applications for installation in hazardous area to be approved in each case according to the DNV Rules and the Ex-Certification/ Special Condition for Safe Use listed in a valid Ex-Certificate issued by a notified/recognised Certification Body.

Operating instructions of the manufacturer to be observed.

Type Approval documentation

Tests carried out

Applicable tests according to Class guideline DNV-CG-0339, August 2021

Applicable tests according IEC 60529, IEC 60079-0, IEC 60079-1, IEC 60079-7, IEC 60079-31*

Marking of product

The products to be marked with:

- manufacturer name
- model name
- serial number

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable).
- Results from Production Sample Tests (PST) and Routines (RT) checked (if not available tests according to PST and RT to be carried out).
- Review of type approval documentation.
- Review of possible change in design, materials and performance.
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE